

July 20, 1977

Mr. John Matthews
Lakewood Mobile Home Park
2710 Fulbright Avenue
Springfield, Missouri 65803

Dear Mr. Matthews:

The results from the sample we took from your treatment plant effluent on June 21, 1977, are as follows:

Biochemical Oxygen Demand	19 mg/l
Suspended Solids	100 mg/l
Fecal Coliform	90,000/100 ml

As you are aware, the limits stated in your NPDES Permit (No. MO-0051195) are BOD - 30 mg/l; SS - 30 mg/l; and Fecal Coliform - 200/100 ml. The results from this particular sample are too high for suspended solids and fecal coliform. The suspended solids are perhaps not representative due to the point at which the sample was taken. However, we are concerned at the level of coliform organisms. This level, 90,000/100ml, is indicative of too low a chlorine residual.

If you so desire, we can test your chlorine residual for you. If you have any questions, or if we can be of further assistance, do not hesitate to call.

Sincerely,

John T. Witherspoon
Water Pollution Control Inspector II
Surveillance & Enforcement

2710 N. Fulbright